

*Proudly presented by*

**Town of Easton Water Division**

2 0 0 2  
**W A T E R**  
QUALITY REPORT



PWS ID#: MA4088000

## Continuing Our Commitment

Once again we proudly present our annual water quality report. This edition covers all testing completed from January through December 2002. We are pleased to tell you that our compliance with all state and federal drinking water laws remains exemplary. As in the past, we are committed to delivering the best quality drinking water. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education, while continuing to serve the needs of all of our water users.



For more information about this report, or for any questions relating to your drinking water, please call John J. Marsh, Superintendent, at (508) 238-0850.

## Where Does My Water Come From?

Easton's water is a groundwater supply consisting of five gravel-packed wells and one well field. The wells are located throughout the town and pump between 350 and 1,000 gallons per minute. Easton's water is distributed to your home through a network of water mains totaling over 156 miles long and ranging in size from 4 to 16 inches in diameter. Currently we have 6,845 active services connected to our system.

## Community Participation

We encourage public interest and participation in community decisions affecting drinking water. The Easton Water Division conducts a yearly open house during the first week in May. The Water Resource Advisory Commission meets regularly. Meeting notices are posted on the board at the Town Hall. The Canoe River Aquifer Advisory Committee meets the first Thursday of each month at locations alternating among the five participating towns. Call (508) 230-0850 for more information. Also, please visit our Web site at [www.easton.ma.us](http://www.easton.ma.us).

## Special Health Information



Some people may be more vulnerable to contaminants in drinking water than the general population.

Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA and CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

## Information on the Internet

The U.S. EPA Office of Water ([www.epa.gov/watthome](http://www.epa.gov/watthome)) and the Centers for Disease Control and Prevention ([www.cdc.gov](http://www.cdc.gov)) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation, and public health. Also, the Massachusetts Department of Environmental Protection has a Web site ([www.MADEP.epa.gov](http://www.MADEP.epa.gov)) that provides complete and current information on water issues in our state.

## Radon

Radon is a radioactive gas that occurs naturally in some ground water. It may pose a health risk when the gas is released from water into air, as occurs during showering or bathing, or washing dishes and clothes. Radon gas released from drinking water is a relatively small part of the total radon in air. Radon is released into homes and groundwater from soil. Inhalation of radon gas has been linked to lung cancer; however, the effects of radon ingested in drinking water are not yet clear. During 2000, samples taken to analyze for radon ranged from 810 to 1,730 picocuries per liter (pCi/L). Currently, radon is not regulated but legislation has been proposed that will allow the U.S. EPA to establish a Maximum Contaminant Level (MCL).

If you are concerned about radon in your home, tests are available to determine the total exposure level. For additional information on how to have your home tested, contact the U.S. EPA's Radon Hotline at (800) SOS-RADON.

## Naturally Occurring Bacteria

The simple fact is that bacteria and other microorganisms inhabit our world. They can be found all around us: in our food, on our skin, in our bodies, and in the air, soil, and water. Some are harmful to us and some are not. Coliform bacteria are common in the environment and are generally not harmful themselves. The presence of this bacterial form in drinking water is a concern because it indicates that the water may be contaminated with other organisms that can cause disease. Throughout 2002 we tested over 650 samples for coliform bacteria. In that time, only one of the samples came back positive for the bacteria. Federal regulations now require that public water that tests positive for coliform bacteria must be further analyzed for fecal coliform bacteria. Fecal coliform are present only in human and animal waste. Because these bacteria can cause illness, it is unacceptable for fecal coliform to be present in water at any concentration. Our tests indicate no fecal coliform is present in our water.



## Contamination from Cross-connections

Cross-connections that could contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems) or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand) causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continuously jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed all industrial, commercial, and institutional facilities in the service area to make sure that all potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

For more information, visit the Web site of the American Backflow Prevention Association for a discussion on current issues at [www.abpa.org](http://www.abpa.org).

## Water Conservation Tips

Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but can also save you money by reducing your water bill. Here are a few suggestions:

### Conservation measures you can use inside your home include:

- Fix leaking faucets, pipes, toilets, etc.
- Old fixtures; install water-saving devices in faucets, toilets and appliances.
- Wash only full loads of laundry.
- Do not use the toilet for trash disposal.
- Take shorter showers.
- Do not let the water run while shaving or brushing teeth.
- Soak dishes before washing.
- Run the dishwasher only when full.

### You can conserve outdoors as well:

- Water the lawn and garden in the early morning or evening.
- Use mulch around plants and shrubs.
- Repair leaks in faucets and hoses.
- Use water-saving nozzles.
- Use water from a bucket to wash your car, and save the hose for rinsing.

Information on other ways that you can help conserve water can be found at [www.epa.gov/safewater/publicoutreach/index.html](http://www.epa.gov/safewater/publicoutreach/index.html).



## Substances Expected to be in Drinking Water

To ensure that tap water is safe to drink, U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals, in some cases, radioactive material; and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

**Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

**Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

**Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

**Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff, and septic systems;

**Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

## What's In My Water?

We are pleased to report that during the past year, the water delivered to your home or business complied with, or did better than, all state and federal drinking water requirements. For your information, we have compiled a list in the tables below showing what substances were detected in our drinking water during 2002. Although all of the substances listed below are under the Maximum Contaminant Level (MCL) set by the U.S. EPA, we feel it is important that you know exactly what was detected and how much of the substance was present in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

### REGULATED SUBSTANCES

SUBSTANCE (UNITS)	YEAR SAMPLED	MCL	MCLG	AMOUNT DETECTED	RANGE (LOW-HIGH)	VIOLATION	TYPICAL SOURCE
Nitrate (ppm)	2002	10	10	2.49	0.79-2.49	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2002	80	0	10.02	NA	No	By-product of drinking water disinfection
Total Coliforms (# of positive samples)	2002	1 positive sample	0	1	NA	No	Naturally present in the environment
Turbidity (NTU) <sup>1</sup>	2002	TT	NA	0.90	NA	No	Soil runoff

Tap water samples were collected for lead and copper analyses from 32 homes throughout the service area

SUBSTANCE (UNITS)	YEAR SAMPLED	ACTION LEVEL	MCLG	AMOUNT DETECTED (90TH% TILE)	HOMES ABOVE ACTION LEVEL	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2001	1.3	1.3	0.707	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb) <sup>2</sup>	2001	15	0	11	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

### UNREGULATED SUBSTANCES

SUBSTANCE (UNITS)	YEAR SAMPLED	AMOUNT DETECTED	RANGE (LOW-HIGH)	TYPICAL SOURCE
Chloroform (ppb)	2001	4.1	ND-4.1	Trihalomethane: By-product of drinking water chlorination or may be naturally occurring.

<sup>1</sup>Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of water quality and the effectiveness of disinfectants.

<sup>2</sup>Infants and young children are typically more vulnerable to lead in drinking water than is the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home plumbing. If you are concerned about elevated lead levels in your home water, you may wish to have your water tested. Flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline at (800) 426-4791.

## Table Definitions

**AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**NA:** Not applicable

**ND:** Not detected

**NTU (Nephelometric Turbidity Units):** Measurement of the clarity, or turbidity, of water.

**ppb (parts per billion):** One part substance per billion parts water (or micrograms per liter).

**ppm (parts per million):** One part substance per million parts water (or milligrams per liter).

**TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.