

Water testing performed in 2004

PWS ID#: MA4088000

Continuing Our Commitment

Once again we proudly present our annual water quality report. This edition covers all testing completed from January through December 2004. We are pleased to tell you that our compliance with all state and federal drinking water laws remains exemplary. As in the past, we are committed to delivering the best quality drinking water. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education while continuing to serve the needs of all of our water users.

For more information about this report, or for any questions relating to your drinking water, please call John J. Marsh, Superintendent, at (508) 238-0850 or e-mail jmarsh@easton.ma.us.



Community Participation

We encourage public interest and participation in community decisions affecting drinking water. The Easton Water Division conducts a yearly open house during the first week in May. The Water Resource Advisory Commission meets regularly. Meeting notices are posted on the board at the Town Hall. The Canoe River Aquifer Advisory Committee meets the first Thursday of each month at locations alternating among the five participating towns. Call (508) 230-0850 for more information. Also, please visit our Web site at www.easton.ma.us.

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhme) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. Also, the Massachusetts Department of Environmental Protection has a Web site (www.mass.gov/dep/dephome.htm) that provides complete and current information on water issues in our state.




Where Does My Water Come From?

Easton's water is a groundwater supply consisting of five gravel-packed wells and one well field. The wells are located throughout the town and pump between 350 and 1,000 gallons per minute. Easton's water is distributed to your home through a network of water mains totaling more than 158 miles and ranging in size from 4 to 16 inches in diameter. Currently we have 7,019 active services connected to our system.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.



Naturally Occurring Bacteria

The simple fact is, bacteria and other microorganisms inhabit our world. They can be found all around us: in our food; on our skin; in our bodies; and, in the air, soil and water. Some are harmful to us and some are not. Coliform bacteria are common in the environment and are generally not harmful themselves. The presence of this bacterial form in drinking water is a concern because it indicates that the water may be contaminated with other organisms that can cause disease. Throughout the year, we tested more than 650 samples for coliform bacteria. In that time, none of the samples came back positive for the bacteria. Federal regulations now require that public water testing positive for coliform bacteria must be further analyzed for fecal coliform bacteria. Fecal coliform are present only in human and animal waste. Because these bacteria can cause illness, it is unacceptable for fecal coliform to be present in water at any concentration. Our tests indicate no fecal coliform is present in our water.

Water Conservation Tips

Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but also can save you money by reducing your water bill. Here are a few suggestions:

Conservation measures you can use inside your home:	You can conserve outdoors as well:
<ul style="list-style-type: none">• Fix leaking faucets, pipes, toilets, etc.• Replace old fixtures; install water-saving devices in faucets, toilets and appliances.• Wash only full loads of laundry.• Do not use the toilet for trash disposal.• Take shorter showers.• Do not let the water run while shaving or brushing teeth.• Soak dishes before washing.• Run the dishwasher only when full.	<ul style="list-style-type: none">• Water the lawn and garden in the early morning or evening.• Use mulch around plants and shrubs.• Repair leaks in faucets and hoses.• Use water-saving nozzles.• Use water from a bucket to wash your car, and save the hose for rinsing.

Information on other ways that you can help conserve water can be found at www.epa.gov/safewater/publicoutreach/index.html.

New Arsenic Regulation

Arsenic contamination of drinking water sources may result from either natural or human activities. Volcanic activity, erosion of rocks and minerals, and forest fires are natural sources that can release arsenic into the environment. Although about 90% of the arsenic used by industry is for wood preservative purposes, it is also used in paints, drugs, dyes, soaps, metals, and semiconductors. Agricultural applications, mining, and smelting also contribute to arsenic releases. Arsenic is usually found in the environment combined with other elements such as oxygen, chlorine, and sulfur (inorganic arsenic); or combined with carbon and hydrogen (organic arsenic). Organic forms are usually less harmful than inorganic forms.

Low levels of arsenic are naturally present in water -- about 2 parts arsenic per billion parts of water (ppb). Thus, you normally take in small amounts of arsenic in the water you drink. Some areas of the country have unusually high natural levels of arsenic in rock, which can lead to unusually high levels of arsenic in water.

In January 2001, the U.S. EPA lowered the arsenic Maximum Contaminant Level (MCL) from 50 to 10 ppb in response to new and compelling research linking high arsenic levels in drinking water with certain forms of cancer. All water utilities are required to implement this new MCL starting in 2006.

Removing arsenic from drinking water is a costly procedure but well worth the expense considering the health benefits. For a more complete discussion visit the U.S. EPA's arsenic Web site at www.epa.gov/safewater/arsenic.html.





Substances That Might Be in Drinking Water

In order to ensure that tap water is safe to drink, the Department of Environmental Protection (DEP) and U.S. Environmental Protection Agency (U.S. EPA) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health. All drinking water, including

bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals, in some cases, radioactive material; and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Radon

Radon is a radioactive gas that occurs naturally in some groundwater. It may pose a health risk when the gas is released from water into air, as occurs during showering, bathing, or washing dishes and clothes. Radon gas released from drinking water is a relatively small part of the total radon in air. Radon is released into homes and groundwater from soil. Inhalation of radon gas has been linked to lung cancer; however, the effects of radon ingested in drinking water are not yet clear. During 2000, samples taken to analyze for radon ranged from 810 to 1,730 picocuries per liter (pCi/L). Currently, radon is not regulated, but legislation has been proposed that will allow the U.S. EPA to establish a Maximum Contaminant Level (MCL).

If you are concerned about radon in your home, tests are available to determine the total exposure level. For additional information on how to have your home tested, contact the U.S. EPA's Radon Hotline at (800) SOS-RADON.

Source Water Assessment and Protection

The Source Water Assessment and Protection (SWAP) program assesses the susceptibility of public water supplies to potential contamination by microbiological pathogens and chemicals. A susceptibility ranking of high was assigned to this system using the information collected during the assessment by the DEP. The complete SWAP report is available at the Water Division Office, 417 Bay Road. For more information, call John J. Marsh, Superintendent, at (508) 230-0850.

Sampling Results

During the past year we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. Although all of the substances listed here are under the Maximum Contaminant Level (MCL), we feel it is important that you know exactly what was detected and how much of the substance was present in the water.

REGULATED SUBSTANCES

SUBSTANCE (UNITS)	YEAR SAMPLED	MCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Haloacetic Acids (HAAs) (ppb)	2004	60	NA	2.8	ND-6.2	No	By-product of drinking water disinfection
Nitrate (ppm)	2004	10	10	2.64	ND-2.64	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2004	80	NA	13.0	2.6-22.7	No	By-product of drinking water disinfection
Turbidity ¹ (NTU)	2004	TT	NA	2.1	0.4-2.1	No	Soil runoff

Tap water samples were collected for lead and copper analyses from 32 homes throughout the service area

SUBSTANCE (UNITS)	YEAR SAMPLED	ACTION LEVEL	MCLG	AMOUNT DETECTED (90th%TILE)	HOMES ABOVE ACTION LEVEL	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2004	1.3	1.3	0.48	0	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead ² (ppb)	2004	15	0	13	3	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

UNREGULATED SUBSTANCES

SUBSTANCE (UNITS)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Chloroform (ppb)	2004	0.6	ND-0.6	(Trihalomethane) By-product of drinking water disinfection; Naturally occurring

¹ Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of water quality and the effectiveness of disinfectants.

² Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline at (800) 426-4791.



Table Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

NA: Not applicable

ND: Not detected

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

Contamination from Cross-Connections

Cross-connections that could contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems) or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand) causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continually jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed all industrial, commercial, and institutional facilities in the service area to make sure that all potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

For more information, visit the Web site of the American Backflow Prevention Association (www.abpa.org) for a discussion on current issues.